

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

Name & Address of Customer : Maple World School Sham Chaurasi Road Kathar Adampur Distt. Jalandhar	Customer Reference No. Sample Submitted by Date of Sample Receipt Analysis Starting Date Analysis completion Date	No : MWS/7073/117 Dated : 03/12/2024 Harwinder Singh 04/12/2024 05/12/2024 08/12/2024
----------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------

Discipline : Bacteriological Testing	Group: Water
U/R No.:	Sample Type : Water
Test Report No. : RWTLHSP/2324/01454	Date of Issue : 08/12/2024
Registration no. : RWTLHSP/REG2324/01547	Condition of Sample : Unsealed
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : RO - 1 / NA
Village: Not Mentioned	Habitation : Not Mentioned
Block: Not Mentioned	District : Hoshiarpur
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method 08/12/2024
3	Bacteriological Contamination	Absent			--	H2S Vial

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur